




WATER TREATMENT



FW & DW KLEEN

REMOVER OF DEPOSITS AND ODORS
FROM FRESH AND DRINKING WATER SYSTEMS

DESCRIPTION

FW & DW KLEEN's composition consists of corrosion inhibitors, special natural acids and active surfactants, that effectively removes scale and lime deposits from the drinking and fresh water system. **FW & DW KLEEN** will also deodorize the system by removing bad and moldy smell. This product is not harmful for the user nor the environment.

APPLICATION

Add **FW & DW KLEEN** in the pipeline system of fresh and drinking water.

USE AND DOSING

Instructions are based on experience and are meant only as a guide since circumstances for each tank cleaning operation vary. They are not intended to interfere with the judgment of the vessel's responsible personnel.

Recirculate **FW & DW KLEEN** for 2-4 hours.

When this process is over, rinse the system with fresh water until pH=7 (neutral).

Use 8-12 ml **CHLOR-ACTIVE** per 1 ton of water to chlorinate fresh water for protection bacterial growth and recirculate.

PRODUCT PROPERTIES

Appearance:	Liquid	pH (undiluted):	Acidic
Type:	Water based	Flash Point:	None

- ✓ Removes deposits
- ✓ Neutralizes odours
- ✓ Non-toxic
- ✓ Biodegradable
- ✓ Cost effective

PROBLEMS SOLVED

- ✓ Dirt in fresh & drinking water systems
- ✓ Unpleasant smell

APPLICATION AREAS

- ✓ Fresh water systems
- ✓ Drinking water systems

PRODUCT CODE: WT 323